

DPS/Engineering Allan E. Schneck, P.E., Director

From:

Jason Boughton

To:

Sara Roediger

Date:

October 1, 2015

Re:

Harvard Place Pool Amendment, City File #04-037.3, Section #24

PUD Amendment Review #1

Engineering Services has reviewed the site plan received by the Department of Public Services on September 23, 2015, for the above referenced project. Engineering Services recommends PUD amendment approval with the following comments to be addressed:

General

1. Revise the city file number to #04-037.3 in the lower right hand corner of all plan sheets.

Sanitary Sewer

1. Provide a revised sanitary sewer basis of design for the overall project.

Water Main

1. Verify the water service size proposed for the building is adequate for this amendment, revise as necessary.

Storm Sewer

1. Revise all the storm sewer detention calculations to take into account the proposed amendment of adding a pool and office/maintenance/pool house compared to the approved construction plans showing an apartment management building only.

The applicant will not need to submit a Land Improvement Permit (LIP) application. Provide engineering with an approved copy once all the comments have been addressed for our record.

JB/bd

c:

Allan E. Schneck, P.E., Director; DPS
Paul Davis, P.E., Deputy Director/City Engineer; DPS
Tracey Balint, P.E., Public Utilities Engineer; DPS
Paul Shumejko, P.E., PTOE, Transportation Engineer; DPS
Keith Depp, Staff Engineer; DPS

Sheryl McIsaac, Office Coordinator; DPS Nick Costanzo, Engineering Aide; DPS Sandi DiSipio; Planning & Development Dept. File