

Architecture

Planning
Interior Architecture

July 19th, 2022

ATTN: City of Rochester Hills Planning and Economic Development

100 Rochester Hills Drive Rochester Hills, MI 48309

RE: Tractor Supply Company

2724 S. Adams Road

Rochester Hills, MI 48309

Below are responses to the reviewed site plan dated 07.13.2022.

Planning

Added legal description to AS1.0.

Building

- Updated plans to coordinate with current building permit construction documents.
- FDC location omitted per Mark Artinian e-mail noting FDC location is not necessary.

Per Josh Boyce of the RH Fire Department (FD), the existing FDC shown on the Site Plan Review and building permit documents on the north side of the building does not exist at that location. There is an existing FDC(s) in other locations and you do not have to identify any of them on either your Site Plan Review or building permit documents. The FD knows where the existing FDC(s) are and they are comfortable with their locations

Engineering

 Added keynote for contractor to set fence at location that puts existing gate valve outside fenced area.

2934 Sidco Drive Suite 120 Nashville, TN 37204 ph 615 256 3455 fax 615 256 3404 Included in addition to this response letter is a site plan package which includes:

AS1.0 Site Plan SL1.0 Sight Lines Site Plan

FP1.0 Fire Protection Site Plan SD1.1 Site Details
ES1.0 Easement Site Plan SD1.2 Site Details
PS1.0 Parking Site Plan Photometric Site Plan

If you should have any questions or need anything else feel free to contact our office.

Sincerely,

Brad Matuzak

Project Manager, Oxford Architecture

615.256.3455 x 15

brad@oxfordarchitecture.com

Amanda Bryant

Project Coordinator, Oxford Architecture

615.927.2106

amanda@oxfordarchitecture.com