Provide an accessible route to the area of sports activity (playing field) from the non-playing field portion of the site per Section 1110.4.1.

SEE WRITTEN RESPONSE TO THIS ITEM

Once on the field, the accessible route(s) to accessible elements (team/player seating/dugouts, accessible bathrooms, drinking fountains etc.) required per Section 1110.4.2, shall comply with A117.1, Section 302.

Are there double doors in this area to the Storage below the Press Box?

YES, THERE ARE DOORS THERE AS INDICATED ON THE BUILDING ELEVATIONS.



This structure does not show up on the Site Plan. Per the clouded comment in the bottom right corner of this sheet, it is assumed that this structure is NOT part of the scope of work for this project.

PLEASE NOTE THAT THE SITE
RENDERING WAS NOT UPDATED AS IT
WAS ONLY INCLUDED FOR
ILLUSTRATOIN OF THE CONCEPT.

munimund

mmmmmmm.

	ISSUE DATE	ISSUED FOR	
	6/20/2022	SITE PLAN REVIEW	_
	12/2/22	SITE PLAN RESUBMITTAL	-
		-	-
		_	-
_	<u> </u>	-	=
_		-	-
_	•	_	-
		-	-
		_	-
		_	-
	DRAWN	REL	
	CHECKED	REL	
	APPROVED.	201	



ROCHESTER UNIVERSITY

ROCHESTER HILLS MICHIGAN

SHEET

AERIAL VIEW
FROM THE NORTHWEST

PROJECT NUMBER

2020-003

SHEET NUMBER

1.01