

June 18th, 2019

Dear City of Rochester Hills,

Regarding: City Review

City File # 19-015

Parcel No. 15-22-451-030

Level One Bank

1880 S. Rochester Road Rochester Hills, MI 48307

The following is in response to the review comments from the city:

Planning & Economic Development – Site Plan – Planning Review #1

Page 2, Item #3

 We updated the photometric study to reduce the maximum fc to be within the zoning ordinance requirements where the maximum fc must not exceed 10 fc. See sheet E-4 for update.

Page 3, Item #7 d, e & f

• These items have been noted and addressed per the zoning requirements and is indicated on sheet L-1 "Landscape Plan"

If there is any disagreement to this letter, then please let me know asap so we can get this resolved as soon as possible. We need confirmation if this acceptable or needs more resolution.

We will update everything as indicated above and resubmit.

Please let us know if there is anything else you may need from us.

Sincerely,

Mark Alfonsi

Principal – Architect - NCARB Certified

MARK RICHARD ALFONSI

1301061858

C.W.SED ARCHITECT

2601 WENDOVE

Phone: (248) 213-6010

ICHIGAN 48302