



Rochester Hills

1000 Rochester Hills Dr
Rochester Hills, MI 48309
(248) 656-4600
Home Page:
www.rochesterhills.org

Master

File Number: 2016-0014

File ID: 2016-0014

Type: Project

Status: To Council

Version: 1

Reference: 15-020

Controlling Body: City Council
Regular Meeting

File Created Date : 01/12/2016

File Name: Woodspring Suites

Final Action:

Title label: Request for Site Plan Approval - Woodspring Suites, a four-story, 48,104 square-foot, 124 unit hotel on 3.64 acres on Marketplace Circle, in the Adams Marketplace Development, land use governed by Consent Judgment, WoodSpring Suites Detroit MI Rochester Hills, LLC, Applicant

Notes:

Sponsors:

Enactment Date:

Attachments: 012516 Agenda Summary.pdf, Tech Compliance Report 011316.pdf, Map aerial.pdf, Review Comments.pdf, Civil Site Plan 120115.pdf, ES-1 Photometric Site Plan.pdf, Woodspring Suites elevations.pdf

Enactment Number:

Contact: PLA 656-4660

Hearing Date:

Drafter:

Effective Date:

History of Legislative File

Ver- sion:	Acting Body:	Date:	Action:	Sent To:	Due Date:	Return Date:	Result:
------------	--------------	-------	---------	----------	-----------	--------------	---------

Text of Legislative File 2016-0014

Title

Request for Site Plan Approval - Woodspring Suites, a four-story, 48,104 square-foot, 124 unit hotel on 3.64 acres on Marketplace Circle, in the Adams Marketplace Development, land use governed by Consent Judgment, WoodSpring Suites Detroit MI Rochester Hills, LLC, Applicant

Body

Resolved, that the Rochester Hills City Council hereby approves the site plan for Woodspring Suites, a four-story, 48,104 square-foot, 124 unit hotel on 3.64 acres on Marketplace Circle, in the Adams Marketplace development, land use governed by Consent Judgment, Parcel No. 15-30-176-010, WoodSpring Suites Detroit MI Rochester Hills, LLC, Applicant, with the following conditions:

Conditions:

1. Per the Building Department memo dated December 29, 2015, show that the Section references are based on the Michigan Building Code 2012; provide elevations around all accessible parking spaces (7); provide confirmation from the Architect that the proposed Use Group Classifications per Section 302 will

be R-1 with Use Group B as an Accessory Use; and correct area analysis using the equation in Section 506.1, at the time of Building Permit submittal.

2. Provide easement agreements in recordable form to create and vacate water main easements as shown on the plans, prior to Issuance of a Land Improvement Permit.
3. Provide storm water maintenance agreements in recordable form, or revise existing as necessary to reflect site improvements, prior to Issuance of a Land Improvement Permit.
4. Relocate the Fire Department Connection (FDC) shown on Sheet SP-2 to the southeast corner of the Building, prior to Final Approval by Staff.
5. Post a Landscape Improvement Bond in the amount of \$68,004.00, prior to issuance of a Land Improvement Permit.