



## FIRE DEPARTMENT

Sean Canto

Chief of Fire and Emergency Services

---

From: Bill Cooke, Assistant Chief / Fire Marshal  
To: Mayor Barnett and City Council Members  
Date: October 31, 2017  
Re: Light the Village  
Display Permit Application  
Village of Rochester Hills – 82 N. Adams

The Fire Department has reviewed the submitted application with the associated documentation and have no objection to the issuance of a fireworks permit, with the following conditions:

1. The display shall be in conformance with the 2014 Edition of NFPA 1123, and the 2006 International Fire Code.
2. During the firing of the display, all personnel in the discharge site shall wear head protection, eye protection, hearing protection, and foot protection and shall wear cotton, wool, or similarly flame-resistant, long-sleeved, long-legged clothing.
3. No smoking shall be allowed in the discharge area where fireworks or other pyrotechnic materials are present.
4. No person shall be allowed in the discharge area while under the influence of alcohol, narcotics, or drugs that could adversely affect judgment, movement, or stability.
5. Subject to onsite inspection the night of the display.

Should you have any questions, please feel free to contact me at (248) 656-4717.