

CITY OF ROCHESTER HILLS

DATE: July 3, 2006

Fire
Department

William Cooke, 2703


TO: Derek Delecourt

RE: Outback Steakhouse
Outdoor Seating

The fire department has reviewed the construction drawings for Outback Steakhouse dated July 13, 2004, and has no objections provided the tables and chairs are made of non-combustible materials and do not obstruct the required width of the exits.

If you have any questions or comments, please do not hesitate to contact me.

I:\fir\forms\ConstructionPlanReview Outback Steakhouse 070306



CITY OF ROCHESTER HILLS

Building
Department

Dick Lange, P.E. Bldg. Insp./Plan Reviewer
Mark McLocklin, Ordinance Services

DATE: June 29, 2006

TO: Derek Delacourt, Planning

RE: Outback Steakhouse
City File #85-543

Sidwell #15-22-451-030

The site plan review for Outback Steakhouse, City File #85-543, was based on the following drawings and information submitted:

Sheet No. FS-1

D.L.

Building code comments: Dick Lange

References are based on the Michigan Building Code 2003.

No comments – Building Permit required.

Ordinance comments: Mark McLocklin *M.*

No comments.

