




HOUSE LEAD DETAIL




STANDARD BEDDING (CLASS B)




FLAT TOP MANHOLE




ADJUSTMENT DETAIL FOR MANHOLE TOPS WITHIN FLOOD PRONE AREAS



ADJUSTMENT DETAIL MANHOLE TOPS WITHIN PAVEMENT AREAS




KOR-N-TEE TAP FOR CONCRETE PIPE



-CAST IRON OR CAST ALUMINUM OR PLASTIC PREMIUM JOINT SADDLE, SEWER TAP OR EQUAL. TO BE INSERTED IN MACHINE- DRILLED HOLE DESIGNED FOR THE PARTICULAR SADDLE.

NOTE: SURFACE OF MAIN SEWER SHALL BE CLEANED WITH AN ABRASIVE GRINDER PRIOR TO EPOXY APPLICATION. DUE TO VARIATION OF SET-UP TIME OF EPOXY ADHESIVE WITH TEMPERATURE, ANCHOR STRAPS SHALL BE USED TO SECURE SADDLE IN POSITION IN COLD WEATHER OR WHENEVER WORK IS TO PROCEED PRIOR TO COMPLETE CURE OF EPOXY.


SEWER TAP-ALL SIZES OF MAIN SEWER PIPES VITRIFIED CLAY




MANUFACTURER'S BUSHINGS IF DISSIMILAR PIPE ARE CONNECTED WATER MAIN REPAIR CLAMPS, SMITH-BLAIR, BAKER, FORD OR EOUAL (ALL STAINLESS STEEL) MAY ALSO BE USED

NOTE: PIPE SHALL BE BEDDED IN STANDARD PLASTIC PIPE BEDDING


WYE PIPE INSERTION WITH FLEXIBLE COUPLINGS (RIGID PIPE)



TESTING BULKHEAD IN EXISTING MANHOLE



FIRST MANHOLE UPSTREAM FROM SANITARY TAP



PROFILE OF BULKHEADS AND ONE FOOT SUMP

CITY OF ROCHESTER HILLS **GRAVITY BUILDING LEAD** REQUIREMENTS AND DETAILS

- 1. ALL BUILDING LEAD WORK MUST BE PERFORMED UNDER THE CITY OF ROCHESTER HILLS INSPECTION.
- 2. FOR ALL CITY OF ROCHESTER HILLS SYSTEMS CALL 248-841-2510 48-HOURS PRIOR TO SCHEDULING INSPECTION
- FOR ALL OCDC-OPERATED SYSTEMS, CALL 248-858-1110 48-HOURS IN ADVANCE PRIOR TO SCHEDULING INSPECTION
- 3. SANITARY SEWER MAY NOT BE USED AS A DEWATERING OUTLET
- 4. WHERE AN EXISTING BUILDING LEAD IS BEING EXTENDED, DISSIMILAR TYPES AND SIZES OF PIPE SHALL BE JOINED USING A CITY OF ROCHESTER HILLS APPROVED ADAPTER.
- 5. APPROVED BUILDING LEAD PIPE FOR GRAVITY SEWER LEADS:
- A. PVC PLASTIC, ASTM D2751, SDR 23.5. B. DUCTILE IRON PIPE, AMERICAN WATER WORKS ASSOCIATION (AWWA) C-104/A21.4, CLASS 54. JOINTS SHALL BE SUPER BEL TITE, TYTON, TY-SEAL, MULTI-TITE, DUAL-TITE, OR VERI-TITE. C. ANY DEVIATIONS FROM ABOVE SPECIFICATIONS REQUIRES APPROVAL BY CITY ENGINEER.
- 6. ALLOWABLE TYPES OF SEWER PIPE ADAPTERS: FERNCO ADAPTER OR FERNCO FLEXIBLE COUPLING
- 7. FOR 6" LEADS A CLEANOUT MUST BE INSTALLED EVERY 100 FT. FOR 4" LEADS A CLEANOUT MUST BE INSTALLED EVERY 50 FT. 90° BENDS NOT ALLOWED EXCEPT FROM THE HORIZONTAL TO THE VERTICAL-WITHIN 5 FEET OF THE BUILDING

CITY OF ROCHESTER HILLS SANITARY SEWER SYSTEM AS-BUILT DRAWING SPECIFICATIONS

IN AREAS WHERE SANITARY SEWER SYSTEMS ARE OPERATED AND MAINTAINED BY THE CITY OF ROCHESTER HILLS DEPARTMENT OF PUBLIC SERVICES, FINAL ACCEPTANCE OF THE SANITARY SEWER SYSTEM MUST BE RENDERED BY THE DEPARTMENT OF PUBLIC SERVICES, BEFORE THE SYSTEM CAN BE USED FOR THE SERVICE INTENDED

ONE ITEM REQUIRED FOR FINAL ACCEPTANCE SHALL BE THE SUBMISSION OF AS-BUILT DRAWINGS TO THE CITY OF ROCHESTER HILLS ENGINEERING DIVISION, BY THE DESIGN ENGINEER. AS-BUILT DRAWINGS SHALL BE DEFINED AS AND CONTAIN THE FOLLOWING INFORMATION:

- 1. FINAL AS-BUILT DRAWINGS SHALL BE PROVIDED ON MYLAR. XEROX OR ANY HEAT PROCESS REPRODUCTIONS WILL NOT BE ACCEPTED.
- 2. ALONG WITH THE MYLAR PLAN SET, PROVIDE THREE (3) SETS OF BLUEPRINTS, PRODUCED FROM THE MYLARS AND THE PLANS ON ELECTRONIC MEDIA IN AUTOCAD FORMAT (LATEST VERSION).
- 3. THE COVER SHEET SHALL BE SEALED BY THE PROJECT DESIGN ENGINEER, ALONG WITH THE FOLLOWING CERTIFICATION STATEMENT

IMPROVEMENTS AS CON IMPROVEMENTS NOTED CONFORMANCE WITH THE	STRUCTED, AND THAT TO AS "AS BUILT" WERE CON HE APPROVED CONSTRUC TRUCTURES, AS CONSTR	ED THESE AS-BUILT DRAWINGS OF THE O THE BEST OF MY KNOWLEDGE THOSE NSTRUCTED IN SUBSTANTIAL CTION PLANS; AND ALSO THAT THE CUCTED, LIE WITHIN THE EASEMENT ESTER HILLS.
	(COMPANY NAME)	
(ENGINEER	S SIGNATURE)	
PROFESSIONAL ENGINE	ER NO.	

ENGINEER SEAL

- 4. THE MAXIMUM SCALE SHALL BE ONE (1) INCH EQUALS FIFTY (50) FEET
- 5. THE SIZE, LENGTH, CLASS AND MANUFACTURER OF PIPE INSTALLED SHALL BE INDICATED
- 6. THE SIZE, MANUFACTURER AND MODEL NUMBERS OF ALL VALVES AND PUMPS INSTALLED SHALL BE
- 7. A TOTAL AS-BUILT DRAWING QUANTITY LIST SHALL BE INCLUDED
- 8. THE LOCATIONS SHALL BE SHOWN ON THE PLANS WITH AN ACCURACY OF ONE (1) FOOT
- 9. THE OFFSET OF THE SANITARY MAIN FROM PROPERTY LINES SHALL BE INDICATED.
- 10. ALL MANHOLES, VALVE WELLS, PUMPS AND ALL SANITARY SYSTEM APPURTENANCES SHALL BE LOCATED FROM TWO FIXED OBJECTS (MANHOLES, BUILDING CORNERS ETC.)
- 11. ALL UNDERGROUND APPURTENANCES, SUCH AS TFC/ARV WELLS, METER PITS, GRINDER PUMPS AND PUMP STATION PITS, ETC. SHALL BE LOCATED FROM THE NEAREST MANHOLE THAT IS CONNECTED TO THE SAME SANITARY MAIN AS THE APPURTENANCE.
- 12. THE ACCURATE LOCATION OF ALL UTILITY CROSSINGS WHERE THE VERTICAL SEPARATION IS LESS THAN 18" SHALL BE NOTED.
- 13. AS-BUILTS SHALL BE PREPARED IN ACCORDANCE WITH CITY OF ROCHESTER HILLS AS-BUILT GUIDELINES AS PROVIDED AT THE PRE-CONSTRUCTION MEETING



City File #73-175.2

REVISIONS CITY COUNCIL, DATE: JULY 21, 2008 NOTIFY ROCHESTER HILLS ENGINEERING DEPARTMENT @ 248-841-2510 48 HRS. PRIOR PREPARED BY ENGINEERING DIVISION TO START OF DEPARTMENT OF PUBLIC SERVICES CONSTRUCTION

City of Rochester Hills

1000 Rochester Hills Drive, Rochester Hills, Michigan 48309

SANITARY SEWER STANDARD DETAILS

NOT TO SCALE

DATE: 7/21/2008

SHEET 2 OF 2

