

**Leanne Scott**

---

**From:** Tracey Balint

**Sent:** Wednesday, May 09, 2007 11:32 AM

**To:** Josy Foisy

**Cc:** Leanne Scott

**Subject:** Adams Marketplace Water & Sanitary Sewer Extension, Easement Revision

The Adams Marketplace Water Main easement has been revised to show an additional 66 ft. of 8" water main to connect Marketplace Circle to Industrial Drive. The City requested this addition. The additional 66 ft. will eliminate a 1400 ft. dead end water main along Industrial Drive.

If you have any questions, please let me know.

Tracey A. Balint, P.E.  
Project Engineer  
City of Rochester Hills

Phone: (248) 841-2504  
Fax: (248) 656-4758