

LIQUOR INSPECTION: ILQ2003-0008
Property : 1711 E AUBURN RD
Sub: Lot: Block:

Parcel: 70-15-25-458-031

Owner : TCS INVESTMENTS LLC Phone:
Occupant : Phone:
Status:
Filed: 10/27/2003 Closed: 10/27/2003

Inspection Information

#: 1 Type: BUILDING Inspector: GARY LUND
Status: Completed Result: Disapproved
Scheduled: 10/27/2003 00:00 am Completed: 10/27/2003 00:00 am
Deficiency: VIOLATIONS
Status: Uncorrected
1-K TYPE FIRE EXTINGUISHER NEAR MOP SINK NOT MOUNTED ON WALL.
2-BEER CASES LOCATED IN AISLE NEAR COOLER, NEAR REAR KITCHEN EXIT AND AT EMPLOYEE RESTROOM DOOR.
3-STORAGE NPT ALLOWED IN EMPLOYEE RESTROOM.
4-EMERGENCY LIGHT IN RESTROOM HALLWAY NOT WORKING PROPERLY.

RE-INSP 10-29-03 BEFORE 10:30 AM

#: 2 Type: ELECTRICAL Inspector: CHARLES LAND
Status: Completed Result: Disapproved
Scheduled: 10/27/2003 00:00 am Completed: 10/27/2003 00:00 am
Comment: NOTE
GROUND POOL TABLE LIGHTS

#: 3 Type: MECHANICAL Inspector: RON WALKER
Status: Completed Result: Disapproved
Scheduled: 10/27/2003 00:00 am Completed: 10/28/2003 00:00 am
Deficiency: CODE VIOLATION
Status: Uncorrected
PROVIDE INSPECTION CLEANING INFORMATION ON KITCHEN HOODS
PROVIDE ROOFTOP ACCESS TO ALL HVAC EQUIPMENT
OWNER TO CALL TO SET UP NEXT INSPECTION

#: 4 Type: PLUMBING & CC Inspector: DEFAULT INSPECTOR
Status: Completed Result: Approved
Scheduled: 10/27/2003 00:00 am Completed: 10/27/2003 00:00 am

#: 5 Type: SITE Inspector: DEFAULT INSPECTOR
Status: Completed Result: Disapproved

Scheduled: 10/27/2003 00:00 am Completed: 10/28/2003 00:00 am
Comment: NOTE
1. REPLACE MISSING HDC SIGN (24 HOURS)
2. AMUSEMENT DEVICES ARE REQUIRED TO BE LICENSED
WITH THE CITY CLERK'S OFFICE.

#: 6 Type: BUILDING Inspector: GARY LUND
 Status: Completed Result: Locked Out
Scheduled: 10/29/2003 00:00 am Completed: 10/29/2003 00:00 am
Deficiency: BUILDING LOCKED OUT
 Status: Uncorrected
 NO ANSWER AT DOORS 9:45AM.

Deficiency: PAY \$100 RE-INSP FEE
Status: Uncorrected

#: 7 Type: SITE Inspector: MARK MCLOCKLIN
 Status: Completed Result: Approved
Scheduled: 01/16/2004 00:00 am Completed: 01/16/2004 00:00 am

LIQUOR INSPECTION: ILQ2003-0025

Property : 2615 S ROCHESTER RD

Parcel: 70-15-26-351-009

Sub: HAMPTON VILLAGE CE Lot: Block:

Owner : NEW PLAN HAMPTON VILLAGE LLC

Phone:

Occupant : OLIVE GARDEN

Phone: 248 853 6960

Status:

Filed: 11/19/2003 Closed: 11/19/2003

Inspection Information

- #: 1 Type: BUILDING Inspector: TIM HOLLIS
Status: Completed Result: Approved
Scheduled: 11/19/2003 00:00 am Completed: 11/19/2003 00:00 am
- #: 2 Type: ELECTRICAL Inspector: CHARLES LAND
Status: Completed Result: Disapproved
Scheduled: 11/19/2003 10:45 am Completed: 11/19/2003 00:00 am
Deficiency: NOTE
Status: Corrected
REPAIR WIRING TO WATER HEATER
REPAIR PULL STATION - FIRE ALARM AT BACK DOOR
REPAIR SWITCHES AT BACK DOOR
- #: 3 Type: MECHANICAL Inspector: RON WALKER
Status: Completed Result: Disapproved
Scheduled: 11/19/2003 00:00 am Completed: 11/19/2003 00:00 am
Deficiency: CODE VIOLATION
Status: Uncorrected
HOOD EXHAUST ON ROOF NOT CLEANED REQUIRED
PROVIDE PERMITS & INSPECTION ON ROOFTOPS REPLACED
HOT WATER HEATER VENTING PRACTICE NEEDS TO BE
CORRECTED
BATH FANS CHECK AFTER REMOD DONE
FIRE PROTECTION ON HOODS OK 7-03 SERVICED
- #: 4 Type: PLUMBING & CC Inspector: RON DREHER
Status: Completed Result: Disapproved
Scheduled: 11/19/2003 00:00 am Completed: 11/19/2003 00:00 am
Deficiency: NOTE
Status: Corrected
BATHROOMS ARE BEING REMODELED, RE-S FOR 11-03-03
- #: 5 Type: SITE Inspector: DEFAULT INSPECTOR
Status: Completed Result: Disapproved
Scheduled: 11/19/2003 00:00 am Completed: 11/20/2003 00:00 am
Deficiency: VIOLATION
Status: Corrected

1. HDC SIGNS NEED TO BE REPLACED (WHITE BACKGROUND, GREEN LETTERS AND BLUE LOGO).
2. CONCRETE CRACKS NEED TO BE REPAIRED. 10 DAYS

#: 6	Type: PLUMBING & CC	Inspector: RON DREHER
	Status: Completed	Result: Approved
	Scheduled: 11/24/2003 00:00 am	Completed: 11/24/2003 00:00 am
#: 7	Type: SITE	Inspector: MARK MCLOCKLIN
	Status: Completed	Result: Approved
	Scheduled: 12/11/2003 00:00 am	Completed: 12/12/2003 00:00 am
#: 8	Type: ELECTRICAL	Inspector: CHARLES LAND
	Status: Completed	Result: Approved
	Scheduled: 01/14/2004 00:00 am	Completed: 01/15/2004 00:00 am
