



May 10, 2024

Jennifer MacDonald  
City of Rochester Hills  
1000 Rochester Hills Drive  
Rochester Hills, MI 48309

Reference: **Old Orion Court Development-CAMS #202400260**  
**Part of the SE ¼ of Section 3, City of Rochester Hills**

Dear Ms. MacDonald,

This office has received a set of plans for the Old Orion Court Development Project to be developed in part of the Southeast ¼ of Section 3, City of Rochester Hills.

Our stormwater system review indicates that the proposed project does not have an involvement with any legally established County Drain under the jurisdiction of this office. Therefore, a storm drain permit will not be required from this office.

The water system is operated and maintained by the City of Rochester Hills and plans must be submitted to the City of Rochester Hills for review.

The sanitary sewer is within the Clinton Oakland Sewage Disposal System. Any proposed sewers of 8" or larger may require a permit through this office.

Any related earth disruption must conform to applicable requirements of Part 91, Soil Erosion and Sedimentation Control of the Natural Resource and Environmental Protection Act, Act 451 of the Public Acts of 1994. Applications should be submitted to our office for the required soil erosion permit.

Please note that all applicable permits and approvals from federal, state or local authorities, public utilities and private property owners must be obtained.

If there are any questions regarding this matter, please contact Dan Butkus at 248-897-2744.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Bennett", is written over a light blue circular stamp.

Brian Bennett, P.E.  
Assistant Chief Engineer

