



# LIVINGSTON ENGINEERING

3300 S. Old U.S.23– Brighton, MI 48114 – 810-225-7100

## Memorandum

**TO:** Mr. Craig Stockard, BRIVAR Constr.

**FROM:** Timm Appleton

**DATE:** January 20, 2010

**SUBJECT:** Legionaries of Christ Worship Center – Response Text.

---

Craig,

The following are the response/plan changes per the latest(City Review #3) for our items:

Building Dept. comments as follows:

1. Sidewalk has been added along the west side of the building from the parking lot to the south side access door of the building.(Architect)
2. See #1 above.
3. Side and rear setback dimensions have been added to sheet #2.
4. (Architect)

Assessing Dept. comments as follows:

- A combined legal description/survey will be completed upon final site plan approval.

Parks and Forestry comments as follows:

- The tree protection fencing has been shown to indicate protection on the side of the trees facing the proposed watermain.
- The note has been corrected.

Public Services Dept. comments as follows:

- It is noted that construction plan approval is required for water main extension.

Fire Dept. comments as follows:

- For clarification, the fire lane detail has been removed. "Fire Lane" signs shall be consistent with the specifications of the Rochester Hills Fire Department.