



**FIRE DEPARTMENT**

Sean Canto  
Chief of Fire and Emergency Services

From: Lee Mayes Captain/Assistant Fire Marshal  
To: Planning Department  
Date: August 13, 2019  
Re: Auburn Rd. Plaza

**SITE PLAN REVIEW**

**FILE NO:19-013.2**

**REVIEW NO: 1**

**APPROVED**     X    

**DISAPPROVED** \_\_\_\_\_

The Rochester Hills Fire Department approves this review. Please note the fire hydrant is not shown on the site plan at the Emmons Avenue Plaza. Please verify where the existing hydrant is located or will this hydrant be relocated.

Lee Mayes  
Captain/Assistant Fire Marshal