

DPS/Engineering Allan E. Schneck, P.E., Director

From: Michael Taunt To: Ed Anzek

Date: September 12, 2014

Re: Regal Estates Condominium City File #13-001, Section 25

#13-001 Regal Estates

Cover Sheet No comments

Sheet 2

- -Add co-ordinate numbers to at least 2 corners on each unit.
- -Add symbols for set/found irons to legend.
- -Show add symbol for set or found monuments and set or found irons at all unit and parcel and boundary corners.
- -Complete the basis of bearing note.
- -City code requires all plats and site condos to be tied to State Plane Coordinates. This can be accomplished by providing SPCs on the two section corners.
- -The boundary of the 25' natural features setback must be described in a retraceable form. A natural features easement, along with legal description and appropriate exhibits, must be provided for Lot 9 and common area.
- -Remove extraneous tie to SW section corner at bottom left corner of drawing. (this applies to sheets 5&6 as well)

Sheet 3

- -Remove crosshatching indicating common area from Jewell Drive.
- -Add Bearings on east & west overall distances to the Jewell Drive ROW.
- -The length of the west side of lot 9 is ambiguous.
- -Add unit coordinate numbers on lots. At least two for every lot are required,.
- -Fill out coordinate tables.
- -Identify building lines by callout or legend.
- -Building lines for lot 5 should nor extend past natural features setback.

Sheet 4

- -Correct fire hydrant symbol in legend.
- -Correct gate valve well symbol in legend.

Sheet 5

-Identify grantee of storm sewer easements.

Sheet 6

-Building lines for lot 5 should nor extend past the natural features setback.

I:\Eng\PRIV\13001 Regal Estates Condos\Final Site Condo Review 1.doc