

**Leslie Accardo**

---

**From:** Scott Sieg  
**Sent:** Monday, August 19, 2024 5:18 PM  
**To:** Leslie Accardo  
**Subject:** FW: 63131-088794-22-3420 ROCHESTER ROAD LLC

---

**From:** Alwan, Hassan (MDOT) <[AlwanH@michigan.gov](mailto:AlwanH@michigan.gov)>  
**Sent:** Wednesday, May 1, 2024 12:55 PM  
**To:** [kennykoza@group10.net](mailto:kennykoza@group10.net); Leslie Accardo <[laccardo@peagroup.com](mailto:laccardo@peagroup.com)>  
**Cc:** Bilan, Wioletta (MDOT) <[BilanW@michigan.gov](mailto:BilanW@michigan.gov)>; Galindo, Steve (MDOT) <[GalindoS@michigan.gov](mailto:GalindoS@michigan.gov)>; Patel, Kajal (MDOT) <[PatelK8@michigan.gov](mailto:PatelK8@michigan.gov)>; Parker, Lisa (MDOT) <[ParkerL15@michigan.gov](mailto:ParkerL15@michigan.gov)>  
**Subject:** 63131-088794-22-3420 ROCHESTER ROAD LLC

You don't often get email from [alwanh@michigan.gov](mailto:alwanh@michigan.gov). [Learn why this is important](#)

**ATTENTION: This email originated from outside of PEA.**

---

MDOT has reviewed the above referenced permit and has the following comments:

OAK-TSC Traffic and Safety

1. TIS appendixes were not provided.
2. Please provide Synchro files.
3. Entering and exiting radii of the driveway on M-59 do not meet the specifications of the MDOT Admin Rules booklet, entering 20' and exiting 15'.
4. Stacking distance for the drive thru should accommodate 16 vehicles at 25' per vehicle or 400'. Please define the stacking length.

We will be placing the permit on hold in CPS while we wait for the above items.

**Hassan Alwan**

MDOT Oakland TSC  
Permit Engineer  
800 Vanguard Dr., Pontiac, MI 48341  
Email: [AlwanH@michigan.gov](mailto:AlwanH@michigan.gov)  
Cell: 313-500-4277

