



FIRE DEPARTMENT
Todd Gary
Chief of Fire and Emergency Services

Date: May 22, 2026

To: Leanne Scott
Kelly McBride

From: Joshua Boyce, Captain/Assistant Fire Marshal

Re: City Fireworks Display Permit Application
Borden Park – 1400 E. Hamlin

The Fire Department has reviewed the submitted application with the associated documentation and has no objection to the issuance of a fireworks permit with the following conditions:

1. The display shall be in conformance with the 2022 Edition of NFPA 1123 and the 2024 International Fire Code.
2. During the firing of the display, all personnel in the discharge site shall wear head protection, eye protection, hearing protection, foot protection and shall wear cotton, wool or similarly flame-resistant, long-sleeved, long-legged clothing.
3. No smoking shall be allowed in the discharge area where fireworks or other pyrotechnic materials are present.
4. No person shall be allowed in the discharge area while under the influence of alcohol, narcotics or drugs that could adversely affect judgment, movement or stability.
5. Subject to onsite inspection the night of the display.

Should you have any questions, please feel free to contact me at (248) 656-4717.